

INSTRUCTIONS FOR INTA GAS & WRAS APPROVED MULTI SLEEVE ISOLATING LEVER BALL VALVES



Intas Gas & WRAS approved multi sleeve isolating ball valves are supplied with three different lever handle sleeves dependant on their intended use at installation;

YELLOW SLEEVE - (already attached to the valve) - for use in Gas installations

BLUE SLEEVE - for use in cold water installations

RED SLEEVE - for use in hot water installations

If the intended use of the valve is for hot or cold water installations, select the correct sleeve and then slide it onto the lever handle leaving the yellow sleeve in place.

THE RED/BLUE SLEEVES ARE DESIGNED TO SLIDE OVER THE YELLOW SLEEVE

DO NOT REMOVE THE YELLOW LEVER HANDLE SLEEVE.

If you encounter difficulty sliding the red and blue sleeves over the yellow lever handle, wipe the yellow handle with a damp cloth to decrease the friction between handle sleeves.